#### **ADDENDUM NO. 1**

## TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace Roofs - Food Service / Dining Building No. 12 Boonville Correctional Center Boonville, Missouri PROJECT NO.: C1905-01

Bid Opening Date HAS CHANGED: 1:30 PM, October 22, 2019 (CHANGED)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

#### **DRAWING CHANGES**

See attached revised Sheets AD-100, A-100, A-500 and A-501.

## SPECIFICATION CHANGES

- 1. Section 001116 Invitation For Bid
  - a. REVISE Paragraph 3.0-A as follows:

A. Until: 1:30 PM, Tuesday, October 22, 2019

- 2. Section 074113 Metal Roof Panels
  - a. REVISE Paragraph 2.4-A as follows:
    - A. Polyisocyanurate Board Insulation: ASTM C 1289, Type II, Class 2, Grade 2 with felt or glass-fiber mat facer on both major surfaces.

# **GENERAL COMMENTS**

- 1. The Pre-Bid Meeting was held on October 8, 2019. The sign-in sheet is attached.
- Bidders requiring additional access to the site for inspection should contact DOC facility staff Bret Fike (DOC - PPS II) or Mike Jewell (DOC - MS II) at (660) 882-6521, <u>Bret.Fike@doc.mo.gov</u> or <u>Mike.Jewell@doc.mo.gov</u> to schedule a time to enter the facility.
- 3. Please contact Kelly Copeland, Contract Specialist, at (573) 522-2283, <a href="Molecular-Kelly-Copeland@oa.mo.gov">Kelly.Copeland@oa.mo.gov</a> for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
- 4. The deadline for submission of technical questions to the Designer was October 10, 2019 at 12:00 pm (noon).

- 5. Changes to, or clarification of, the bid documents are only made as issued in the addenda. No bidder shall be entitled to rely on oral interpretations as to the meaning of the plans and specifications or the acceptability of alternate products, materials, form or type of construction.
- 6. All correspondence with respect to this project must include the State of Missouri project number as indicated above (C1905-01).
- 7. The list of Current Planholders is available online at: <a href="https://www.adsplanroom.net/jobs/190/plan-holders/c1905-01-replace-roofs-boonville-correctional-center">https://www.adsplanroom.net/jobs/190/plan-holders/c1905-01-replace-roofs-boonville-correctional-center</a>
- 8. Prospective Bidders are advised to contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, (573) 446-7768 to obtain plans and specifications.

## <u>ATTACHMENTS</u>

- 1. Pre-Bid Meeting Sign-In Sheet
- 2. Revised Drawing Sheets AD-100, A-100, A-500 and A-501

October 10, 2019 END ADDENDUM NO. 1